

CERTIFICATE OF COMPLIANCE

This certificate confirms the model(s) for the product listed are in compliance and authorized to bear the Certification Mark(s) shown below when made in accordance with the conditions set forth in the Certification Agreement and Listing Report.

Macurco Inc

Address: 1504 W 51st St
Sioux Falls, SD, 57105

Country: USA

Report Issuing Office: Intertek Testing Services NA, Inc., Arlington Heights, IL

Control Number: 4006280

Authorized by: 
for L. Matthew Snyder, Certification Manager

VALID LISTING MARKS



This Certificate of Compliance is for the exclusive use of Intertek's Client and is provided pursuant to the Certification Agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the Agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the Agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the Agreement and in this Certificate. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the Agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667

Standard(s):	Gas and Vapor Detectors and Sensors [UL 2075:2013 Ed.2+R:31Aug2021] Standard for Gas and Vapour Detectors and Sensors, Including Accessories [CAN/ULC S588:2017 Ed.1]
Product:	Combustible Gas Detector, Controller and Transducer
Brand Name:	Macurco
Models:	GD-6
Product Description:	The product covered by this report is a gas detector intended for commercial applications. It measures the amount of Methane (NG) in the surrounding environment. It goes into alarm or activates exhaust fan depending amount methane present. The product can be programmed to

CERTIFICATE OF COMPLIANCE

	perform different functions based on the methane concentration in the air. It can be calibrated in the field, and it can be connected to the Listed Horn/Strobe (Manufacturer: Macurco; Models 70-2900-0161-8, 70-2900-0162-9, 70-2900-0163-0, 70-2900-0164-1, 70-2900-0165-2). The product must be installed and used in accordance with all local codes.
--	--