

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 5275-2071:0101

CATEGORY: Gas/Vapor Detectors

LISTEE: Aerionics, 3601 N St. Paul Ave., Sioux Falls, SD 57104
Contact: Jeffrey Christiansen (512) 524-3414 Fax (512) 524-3415
Email: jchristiansen@aerionicsinc.com

DESIGN: Model GD-2A Four-wire gas detector. Detector is intended for use with a listed alarm control panel. The GD-2A does NOT detect carbon monoxide. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 - 24 VDC or VAC

INSTALLATION: In accordance with listee's printed installation instructions, and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, Model number, electrical rating and UL label.

APPROVAL: Listed as a gas detector for use with listed alarm control panel.

NOTE: Gas detectors are not intended/suitable for fire and smoke detection.

07-29-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division